



Fire Detectors

Fire detectors are available for residential, commercial, and industrial use. Models are available for both single and multiple stations, as well as system applications. There are a number of different types of detectors available, including smoke, flame, heat, and gas detectors. This handout provides basic information on the operation and application of fire detectors.

Smoke Detectors

Smoke detectors are designed to provide early warning for a fire, involving ordinary combustible materials, that is expected to progress through distinct incipient and/or smoldering stages. The type, volume, and density of smoke produced during the fire development process will vary greatly depending on the fuels involved and the amount of oxygen available. Typically, the greatest volume of visible smoke is produced during the ignition (incipient) stage and the smoldering stage.

While there are a number of different types of smoke detectors available, the two most commonly used smoke detectors are the ionization and photoelectric types.

Ionization Detectors

The ionization smoke detector reacts to both visible and invisible products of combustion. This spot-type detector contains a small radiation source that produces electrically charged air molecules called ions. The use of a long, half-life radioactive source, coupled with low energy consumption, gives the ionization detector long life expectancy with minimal maintenance. Ionization-type detectors respond better to a flaming fire.

Ionization detectors are not suitable for use in applications where high ambient radioactivity levels are to be expected. High ambient radiation reduces the detector's sensitivity. Ionization detectors have been known to react to non-fire-generated particles of combustion and the presence of ozone, ammonia, or insects. Single chamber ionization detectors installed in higher altitudes usually require a modification in sensitivity during installation.

Photoelectric Detectors

There are two types of photoelectric detectors: beam and light scattering, both of which consist of a light source, a collimating lens system, and a photosensitive cell. In a beam-type photoelectric detector, a light beam is directed at a photocell; when smoke interferes with the beam, the infrared light reaching the receiver drops, initiating a signal. The light scattering photoelectric detector detects smoke by sensing the light reflected by smoke particles. When the smoke particles are dense enough to reflect a predetermined amount of light, the detector's circuit actuates the alarm. Photoelectric detectors respond better to a smoldering fire.

Air Sampling Detectors

Air sampling detectors draw a small amount of air from a target area into a detection device. Typically, these samplers use a light scattering detection method to analyze the particles found in the sampled air. These detectors can be calibrated to produce a high degree of sensitivity based on the area protected.



Linear Beam Smoke Detectors

The linear beam smoke detector operates on the same principle as the photoelectric smoke detector in that a light source is directed on a photosensitive receiver. The difference is that this type of detector consists of two separate units: a light source, or transmitter, that emits an invisible infrared beam, over open-area distances of 35 to 300 ft (10.7 to 91.4 m), and a light receiver. This type of smoke detector has many applications, such as atriums, airport terminals with very high ceilings, aircraft hangars, churches, and large open facilities.

Smoke Detector Use

Smoke detectors are designed to provide early warning for a fire, involving ordinary combustible materials, that is expected to progress through distinct incipient and/or smoldering stages. The type, volume, and density of smoke produced during the fire development process will vary greatly depending on the fuels involved and the amount of oxygen available. Typically, the greatest volume of visible smoke is produced during the ignition (incipient) stage and the smoldering stage.

Smoke Detector Effectiveness

Even with ready access to low cost and, at times, free smoke detectors, exposure to fire and smoke is responsible for thousands of deaths and billions of dollars in property damage each year. One challenge for many property owners is determining what type (i.e., design) of smoke detector to purchase and where to install the units. Some detectors are more effective (respond quicker) to flaming combustion, while others respond better to smoldering combustion. Likewise, some detectors are more prone to false activation from environmental factors than others.

The 2011 National Fire Protection Association (NFPA) Report, "Smoke Alarms in US Home Fires," indicates that 385 of the home fire deaths occurred where there were no detectors. Further, the report reveals that 50% of the detectors that failed to operate were missing batteries, 23% had dead batteries, and 7% had the power disconnected. In short, the single greatest cause of detector failure does not have to do with the type of detector, but with a lack of power to the detector.

The NFPA smoke detector webpage offers the following advice: "For each type of smoke alarm, the advantage it provides may be critical to life safety in some fire situations. Home fatal fires, day or night, include a large number of smoldering fires and a large number of flaming fires. You cannot predict the type of fire you may have in your home or when it will occur. Any smoke alarm technology, to be acceptable, must perform acceptably for both types of fires in order to provide early warning of fire at all times of the day or night and whether you are asleep or awake."

In general, photoelectric detectors respond better to a smoldering fire and ionization-type detectors to a flaming fire. To address the differences in detector types, nearly all of the major manufacturers offer dual (ion and photo) sensor detectors. Additionally, most risk control specialists recommend that carbon monoxide detectors also be installed to ensure that all possible combustion products are detected.

Flame Detectors

Flame detectors are primarily intended to protect areas where anticipated fires will develop quickly, with little or no incipient or smoldering stages, or where ignition is almost instantaneous (i.e., flammable liquids and combustible gas fires, explosions, and flash fires). A flame detector optically senses radiation given off by flames or glowing embers. Types of flame detectors include:



Infrared (IR) Flame Detectors

The infrared flame detector senses light at the extreme, high end of the light spectrum. Flicker-flame detectors are infrared detectors capable of sensing the typical flicker of a flame. With the flicker-flame unit, if the initial flames are directly hidden from the unit, the flickering light (or radiation) being reflected, such as off a ceiling or wall, is adequate for initiating an alarm.

Ultraviolet (UV) Light Detectors

The ultraviolet flame detector's sensing element usually consists of either a solid-state device, such as silicon carbide or aluminum nitride, or a gas-filled tube in which the gas is ionized by ultraviolet radiation. This causes the materials to become conductive, resulting in the initiating of an alarm.

Combination Flame Detectors

Combination UV/IR flame detectors are designed to see portions of both light spectrums and use the resulting composite signal to initiate an alarm. These detectors generally require both UV and IR light sources fitting a particular frequency to cause an alarm. This process results in fewer false alarms due to the finite combinations of frequencies accepted.

Spark Detectors

While not a true flame detector, spark detectors identify radiant energy produced by sparks and embers in closed environments, such as air ducts. Sparks produce both IR and visual light, and as such, these detectors detect those light spectrums and, through processing circuits, initiate a signal based on the concentrations of these two sources.

Heat Detectors

Heat detectors respond to the thermal energy of a fire. They are generally located at or near the ceiling of a building and are best suited for fire detection in small confined spaces where rapidly growing, high-heat output fires may be expected. Heat detectors are designed to sense a pre-described change in the physical or electrical property of a material exposed to heat. They may respond either at a fixed temperature, a specified rate of temperature change, or both.

Fixed Temperature Detectors

Fixed temperature detectors (spot or continuous line type) are designed to activate an alarm when the temperature of the operating element reaches a specified value. Spot detectors are located in a protected area and each provides an independent initiation source. Continuous line types consist of a pair of wires in a twin wire or a coaxial type of conductor that stretches across the protected area. When the wire's insulation melts, under fire conditions, the wires short, causing an alarm.

Rate-of-Rise Detectors

One effect that a fire has on the surrounding environment is to generate a rapid increase in the air temperature in the area above the fire. The rate-of-rise detector is designed to activate when the rate of temperature change exceeds a predetermined value, typically around 15°F (8.3°C) per minute.

Combination Rate-of-Rise/Fixed Temperature Detectors

Combination detectors are designed to incorporate both rate-of-rise and fixed temperature detectors into one unit. Rate-of-rise detectors will not activate if the rate of temperature rise is less than the specified value, and thus, extreme temperatures might be permitted to develop slowly with no alarm. For this reason, heat detection devices that operate on both the rate-of-rise and fixed temperature principles are available.



Gas Detectors

Gas detectors operate by sensing gases produced by a fire. The presence of certain gases, or aerosols, causes a reduction in the surface resistance of the sensor, resulting in an increased current flow that is used to trigger an alarm. This device will only detect fires that burn with incomplete combustion, which produce significant quantities of gases, as opposed to fires that burn with complete combustion and produce relatively little or no gases.

COPYRIGHT ©2013, ISO Services, Inc.

CH-25-51 4/17/13

The information, suggestions and recommendations contained herein are for general informational purposes only. This information has been compiled from sources believed to be reliable. Risk Consulting Services do not address every possible loss potential, law, rule, regulation, practice or procedure. No warranty, guarantee, or representation, either expressed or implied, is made as to the correctness or sufficiency of any such service. Reliance upon, or compliance with, any recommendation in no way guarantees any result, including without limitation the fulfillment of your obligations under your insurance policy or as may otherwise be required by any laws, rules or regulations. No responsibility is assumed for the discovery and/or elimination of any hazards that could cause accidents, injury or damage. The information contained herein should not be construed as financial, accounting, tax or legal advice and does not create an attorney-client relationship.

This document is not intended to replace any recommendations from your equipment manufacturers. If you are unsure about any particular testing or maintenance procedure, please contact the manufacturer or your equipment service representative.

American International Group, Inc. (AIG) is a leading global insurance organization. AIG member companies provide a wide range of property casualty insurance, life insurance, retirement solutions, and other financial services to customers in more than 80 countries and jurisdictions. These diverse offerings include products and services that help businesses and individuals protect their assets, manage risks and provide for retirement security. AIG common stock is listed on the New York Stock Exchange. Additional information about AIG can be found at www.aig.com | YouTube: www.youtube.com/aig | Twitter: [@AIGinsurance](https://twitter.com/AIGinsurance) | www.twitter.com/AIGinsurance | LinkedIn: www.linkedin.com/company/aig. These references with additional information about AIG have been provided as a convenience, and the information contained on such websites is not incorporated by reference into this document.

AIG is the marketing name for the worldwide property-casualty, life and retirement, and general insurance operations of American International Group, Inc. For additional information, please visit our website at www.aig.com. All products and services are written or provided by subsidiaries or affiliates of American International Group, Inc. Products or services may not be available in all countries and jurisdictions, and coverage is subject to underwriting requirements and actual policy language. Non-insurance products and services may be provided by independent third parties. Certain property-casualty coverages may be provided by a surplus lines insurer. Surplus lines insurers do not generally participate in state guaranty funds, and insureds are therefore not protected by such funds.

© American International Group, Inc. All rights reserved.